



Specialists in School Buildings

DATE: January 26, 2015
RE: Change Order No. 18
Board Summary
Project: New Woodland High School

Change Order 18 amount: \$43,583.00

- CCD 086 – The fire alarm annunciation in the Grandstand is required to be a voice capable system. The main fire alarm panel in the main building was revised under this change to provide microphone communication capabilities to communicate with the Grandstand. This was a code required change.
- CCD 097 – This was for additional labor and materials to provide electrical power to the low voltage power supplies which control lock down devices on exterior doors. The power was not shown on the drawings.
- COP 054 – Provide an additional outlets in the Safe Room 1101A in Administration Area as requested by admin team.
- COP 055 – Provide auto controller for kiln venting in Art as requested by art instructor.
- COR 206 - Change to wall stud framing to 8" to make adequate room to fit the structural steel within the wall. Drawings showed 6" studs.
- COR 207 – Credit for smoke detectors that were not needed.
- COR 210 – Revise intrusion alarm control panel programming and provide additional door contacts not shown on drawings.
- COR 327 – At the 2-hour fire wall, add 4 fire smoke dampers in HVAC ducts including devices, controllers and wiring between Rooms 2402/2402A and Rooms 2201/2201A. Not shown on drawings.
- COR 257 – This is to provide additional fasteners at the exterior window flashing to improve water tightness and reduce sealant joint width.

CSG Office Locations

ESD 112
2500 NE 65th Avenue
Vancouver WA 98661
P 360.750.7500
F 360.750.9706

ESD 101
4202 S Regal Street
Spokane WA 99223
P 509.789.3800
F 509.456.2999

ESD 123
3918 W Court Street
Pasco WA 99301
P 509.547.8441
F 509.544.5795

ESD 171
430 Olds Station Road
Wenatchee WA 98801
P 509.665.2610
F 509.662.9027

NW ESD 189
1601 R Avenue
Anacortes WA 98221
P 360.299.4000
F 360.299.4070



End