



Specialists in School Buildings

DATE: April 27, 2015  
RE: Change Order No. 24  
Board Summary  
Project: New Woodland High School

---

Change Order amount: \$58,489.00

- CCD 090 – There were three ice makers (Concessions at Gyms, Concessions at Grandstand and Team Room) that had no power or drains shown for them on the drawings. This change order added those utilities as well as revisions to finishes to accommodate the work.
- CCD 120 – The drawings did not show the bars and clips for the theatrical light attachment serving the Stage at the Commons. Added per this change.
- CCD 122 – Revise sprinkler head locations in north and south Shared Activity Areas to avoid conflict with lettering of inspirational quotes.
- CCD 126 – Provide block out and additional concrete to create recessed area to install fund raising bricks in sidewalk near Grandstand.
- COP 060 – Provide water distribution system (piping and hose bibs) as well as hanging basket rods, drip irrigation system and misting system to green house. Included power for equipment. Not shown on drawings.
- COP 071 – Revise sidewalk to Grandstand to accommodate accessible pedestrian curb cuts.
- COR 295 – Provide electrical power to fire and smoke dampers in HVAC ducts. Not shown on drawings.
- COR 301 – Provide additional asphalt paving around fence posts to create mow strip. Long term maintenance improvement.
- COR 331 – Provide electrical power for fans, heaters and cooler (pump and fans) in green house. Not shown on drawings.

End

#### CSG Office Locations

ESD 112  
2500 NE 65th Avenue  
Vancouver WA 98661  
P 360.750.7500  
F 360.750.9706

ESD 101  
4202 S Regal Street  
Spokane WA 99223  
P 509.789.3800  
F 509.456.2999

ESD 123  
3918 W Court Street  
Pasco WA 99301  
P 509.547.8441  
F 509.544.5795

ESD 171  
430 Olds Station Road  
Wenatchee WA 98801  
P 509.665.2610  
F 509.662.9027

NW ESD 189  
1601 R Avenue  
Anacortes WA 98221  
P 360.299.4000  
F 360.299.4070